

NOTE:

- 1. PVC/DHPE Weep holes of 90 mm dia. Opening shall be provided staggered both horizontally at 1.5m interval and vertically at 1 m interval.
- 2. 600mm width of filter media composed of good quality stones. (50-100mm) shall be provided
- 3. A panel separation gap has to be provided at maximum of 8-10 m length of wall. The gaps are also to be provided at bends and junctions.
- 4. 10mm or thicker cement mortar ratio of 1:5 (cement: sand) or higher grade shall be provided between each stone element.

## SCHEDULE OF RRM WALL

sl No	H(m)	t (mm)	D (mm)	Remarks
1	<=0.6<1.0	300	250	PROVIDES
2	> 1.0<=1.2	350	300	T=600
3	>12<=15	400	400	WHERE
4	> 1.5<=2.0	500	600	E VER T HE
5	>2.0<=2.5	600	600	WITCH
6	>2.5<=3.0	600	700	YARD
7	>3.0<=4.0	600	800	FALLS
8	>40<=5.0	300	900	


H - Height above GL.

t - Top Width

D - Depth below ground level.

B – Base width.





**TITLE** REPAIR AND MAINTENANCE OF EXCESS ROAD, CHP

## NOTICE OF THE CONSULTANTS/SUPERVISION TEAM - MINOR ADJUSTMENTS NEED TO BE CARRIED OUT ON SITE TO MATCH WITH EXISTING SITE SITUATION

CLIENPT	design by	NORAWN BYHER	<sub>NG</sub> DATE	A PORAWING NO
	ENGINEER	SCANES	SR	-01
PLOT NO				

CIVIL MAINTENANCE SECTION

